

Building Renewal Grant Application

Initial Submission Date: 10/3/2012 2:25:55 PM

Application ID: 316

Resubmittal Date:

Please provide as much of the requested information as possible. SFB staff will assist in developing required information that is not currently available.

District Name: Laveen Elementary District

Superintendent: Dr Bill Johnson

Contact Person: Everette E Cole

Contact Phone Number: 602-237-9100

Contact Email: ecole@laveeneld.org

School Site: Desert Meadows

Buildings: 1003 Building C

Description of Problem

Please include a detailed description of the issues, as well as a description of and a copy of any professional studies, citations or reports from government entities, recommended solutions, and any cost information or estimates. If additional space is needed, please attach.

The windings are grounded in the 5 ton Carrier compressor for classroom 21 at Desert Meadows school. The compressor is approximately 7 years old and therefore is not under any kind of warranty. The cost for the compressor, including a filter dryer from Sigler and Reeves is. I have attached a copy of the quote to this grant

Project Category: HVAC

Are any of the above-described issues in buildings or part of buildings that are leased to another entity, including a district sponsored charter school? N

Available Funding

Current unencumbered building renewal fund balance (Fund 690):	\$0.00
Amount of Local funds planned for this project	\$0.00

Please outline any associated insurance coverage.

In accordance with our Insurance policy A.3 Section 15.2 Perils Excluded, loss by or resulting from wear and tear to covered property is not covered. Therefore, the District must cover this expense themselves.

Liaison: Cruse

pcruse@azsfb.gov

602-364-1193

Superintendent Printed Name

Building Renewal Grant Application

Superintendent Signature

Date